

BUILDING SAFETY CERTIFICATE

APPNENDIX-XI

No. 810

Dated: 14/5/25

Certified that the existing building "GOVT. MODEL SANSKRITI SR. SEC. SCHOOL" (name of the building or premises) at SIHMA (3899) (address) comprised of No Basement (name of the basement(s) and No Upper Floors (upper floors) owned/occupied by The Principal, GOVT. MODEL SANSKRITI SR. SEC. SCHOOL, SIHMA (3899) (name of the Institution) have complied with the Building safety requirements in accordance with National Building code Rules, and verified by the officers concerned of PWD B&R Br., NARNAUL (Name of Department/ Govt.) on 13.05.2025 (date of Inspection) in the presence of Sh. Krishan Kumar, Principal of GOVT. MODEL SANSKRITI SR. SEC. SCHOOL, SIHMA (name and addresses of the Manager/Secretary or his representative) and that the building/premises is fit for occupancy upto classes XII (X/ XII) with effect from 13.05.2025 to 31.03.2026 for a period of 0 year 11 Months in accordance with rule and subject to compliance of the specific conditions as appended.

1. The building safety certificate letter received from the Principal GSSS Sihma vide his Memo No. 09/2025 dt. 28.04.2025 received in this Office on dated 06.05.2025.
2. The building was neither constructed by PWD B&R department nor under their Supervision. Moreover, implementation of National Building Code Rule in accordance of Building Safety requirement fully governed by institute Head.
3. The corridor roof of some places & dome class rooms required urgent repair and installation of door on staircase is also required for unauthorized entry.
4. The existing school building needs special repair/annual maintenance. (keep building structurally safe)
5. At present, the subject school building seems structurally safe by visual inspection.
6. The issued certificate is not valid for any legal purposes / court evidence.

issued on: 14.05.2025 at Narnaul by

*Strike out whichever is not applicable.

Signature with Seal:

Name:

Sh. Alok Kumar

Designation:

Sub Divisional Engineer

Name & Address of Department/ Office:

Provl. Sub Divn. No. 1, PWD

B&R Br., Narnaul

(Assistant Engineer & above officer of concerned Govt. Department only)

Note: This certificate should be signed / Issued by Assistant Engineer & above officer of concerned Govt. Department only

* The filled up certificate should be either in Hindi or English. If it is issued in Vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.